


Power House Basement Sump Pump Pit Inspection Form

Pit covers must remain on at all times

Date: 1-26-17

Time: 9:00 AM

Initials: R.L.



Sump Pits	Clean	Oil Sheen	Comments
70k Room	✓		
6 Turbo Blower	✓		
7 Generator		Some oil	Will have cleared today
5 Turbo Blower	✓		SENDING TO ASH PIT
7 Turbo Blower	✓		
2300VAC Room	✓		
8 Generator	✓		

If oil is found in sump pit contact KM to have the pit cleaned out.


Power House Basement Sump Pump Pit Inspection Form

Pit covers must remain on at all times

Date: 1-25-17

Time: 5:45 P.

Initials: RLC



Sump Pits	Clean	Oil Sheen	Comments
70k Room	✓		
6 Turbo Blower	✓		
7 Generator		SOME OIL	K+M IS CLEANING
5 Turbo Blower		SOME OIL	BEING SENT TO ASHPIT
7 Turbo Blower	✓		
2300VAC Room	✓		
8 Generator		SOME OIL	K+M IS CLEANING

If oil is found in sump pit contact KM to have the pit cleaned out.